

PERMITTEE NAME/ADDRESS:

NAME: ANCHORAGE, MUNICIPALITY OF
ADDRESS: 3000 ARCTIC BLVD.
ANCHORAGE AK 99503-3898

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

AK0022551
PERMIT NUMBER

001 A
DISCHARGE NUMBER

MAJOR
(SUBR 02)
F - FINAL

Form Approved
OMB No. 2040-0004

FACILITY: JOHN M. ASPLUND WWTF---301 (H)
LOCATION: ANCHORAGE, AK 99502
ATTN: MARK PREMO P.E. GEN MGR. AWWU

MONITORING PERIOD

FROM 06 | 07 | 01 TO 06 | 07 | 31

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNIT			
TEMPERATURE, WATER DEG. CENTIGRADE 00010 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	*****	*****	***	*****	*****	14.9	(04)	N/A	FOUR/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	***	*****	*****	REPORT MAXIMUM	DEG.C		FOUR/ WEEK	GRAB
TEMPERATURE, WATER DEG. CENTIGRADE 00010 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	*****	15.3	(04)	N/A	FOUR/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	***	*****	*****	REPORT MAXIMUM	DEG.C		FOUR/ WEEK	GRAB
OXYGEN, DISSOLVED (DO) 00300 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	1.5	*****	*****	(19)	N/A	FOUR/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	***	REPORT MIN	*****	*****	MG/L		FOUR/ WEEK	GRAB
BOD, 5-DAY (20 DEG. C) 00310 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	52311	*****	(26)	*****	237	*****	(19)	N/A	FOUR/ WEEK 1)	COMP24
	PERMIT REQUIREMENT	REPORT MO AVG	*****	LBS/DY	*****	REPORT MO AVG	*****	MG/L		FOUR/ WEEK	COMP 24
BOD, 5-DAY (20 DEG. C) 00310 W 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	42865	(26)	*****	*****	188	(19)	0	FOUR/ WEEK 1)	COMP24
	PERMIT REQUIREMENT	*****	90100 DAILY MX	LBS/DY	*****	*****	300 DAILY MX	MG/L		FOUR/ WEEK	COMP 24
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	34130	40428	(26)	*****	155	179	(19)	0	FOUR/ WEEK 1)	COMP24
	PERMIT REQUIREMENT	72100 MO AVG	75100 WKLY AVG	LBS/DY	*****	240 MO AVG	250 WKLY AVG	MG/L		FOUR/ WEEK	COMP 24
PH 00400 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	*****	*****	***	6.8	*****	7.4	(12)	N/A	FOUR/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	***	REPORT MINIMUM	*****	REPORT MAXIMUM	SU		FOUR/ WEEK	GRAB

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER

J. Kris Warren
Director, Treatment Division

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. §1001 AND 33 U.S.C. §1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

(907)564-2799

AREA CODE NUMBER

DATE

06/08/08

YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

BOD results for 7/26 & 27/2006 invalid due to lab error - therefore, only two valid tests during that week. Three extra BOD tests were run earlier in the month.

Forms by WindowChem(707)954-0845;ph11090;v5.01;4/1/96. Rev. 1/05, BN

PERMITTEE NAME/ADDRESS:

NAME: ANCHORAGE, MUNICIPALITY OF
ADDRESS: 3000 ARCTIC BLVD.
ANCHORAGE AK 99503

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

AK0022551
PERMIT NUMBER

001 A
DISCHARGE NUMBER

MAJOR
(SUBR 02)
F - FINAL

Form Approved
OMB No. 2040-0004

FACILITY: JOHN M. ASPLUND WWTF---301 (H)
LOCATION: ANCHORAGE, AK 99502
ATTN: MARK PREMO P.E. GEN MGR. AWWU

MONITORING PERIOD

FROM 06 | 07 | 01 TO 06 | 07 | 31


*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNIT			
PH	SAMPLE MEASUREMENT	*****	*****	***	6.8	*****	7.1	(12)	0	FOUR/ WEEK	GRAB
00400 1 0 0	PERMIT REQUIREMENT	*****	*****	***	6.5 MINIMUM	*****	8.5 MAXIMUM	SU		FOUR/ WEEK	GRAB
EFFLUENT GROSS VALUE											
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	59852	*****	(26)	*****	268	*****	(19)	N/A	FOUR/ WEEK	COMP24
00530 G 0 0	PERMIT REQUIREMENT	REPORT MO AVG	*****	LBS/DAY	*****	REPORT MO AVG	*****	MG/L		FOUR/ WEEK	COMP24
RAW SEW/INFLUENT											
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	15841	(26)	*****	*****	72	(19)	0	FOUR/ WEEK	COMP24
00530 W 0 0	PERMIT REQUIREMENT	*****	57000 DAILY MX	LBS/DAY	*****	*****	190 DAILY MX	MG/L		FOUR/ WEEK	COMP24
EFFLUENT GROSS VALUE											
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	12051	13144	(26)	*****	54	58	(19)	0	FOUR/ WEEK	COMP24
00530 1 0 0	PERMIT REQUIREMENT	51000 MO AVG	54000 WKLY AVG	LBS/DAY	*****	170 MO AVG	180 WKLY AVG	MG/L		FOUR/ WEEK	COMP24
EFFLUENT GROSS VALUE											
NITROGEN, AMMONIA TOTAL (AS N)	SAMPLE MEASUREMENT	*****	*****	***	*****	21.4	*****	(19)	N/A	ONCE/ MONTH	COMP24
00610 1 0 0	PERMIT REQUIREMENT	*****	*****	***	*****	REPORT MO AVG	*****	MG/L	N/A	ONCE/ MONTH	COMP24
EFFLUENT GROSS VALUE											
FECAL COLIFORM, MPN, EC MED, 44.5C	SAMPLE MEASUREMENT	*****	*****	***	*****	229	*****	(30)	1	THREE/ WEEK	GRAB
31615 1 0 0	PERMIT REQUIREMENT	*****	*****	***	*****	850 MO GEO	*****	MPN/ 100ML		THREE/ WEEK	GRAB
EFFLUENT GROSS VALUE											
FLOW IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	26.917	*****	MGD	*****	*****	*****	****	N/A	CONTINUOUS	RCORDR
50050 1 0 0	PERMIT REQUIREMENT	MO AVG	*****	MGD	*****	*****	*****	****		CONTINUOUS	RCORDR
EFFLUENT GROSS VALUE											

J. Kris Warren
Director, Treatment Division
TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY KNOWLEDGE OF THOSE FACTS AND MY JUDGMENT, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. §1001 AND 33 U.S.C. §1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)


SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE
(907)564-2799
AREA CODE NUMBER

DATE
06/08/08
YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

1) Permit has a fecal coliform limit that reads "Not more than 10% of the samples shall exceed 2600 FC MPN/ 100 mL." Two samples during July exceeded 2600 FC MPN/100 mL, which exceeds the 10% limit. Letter of explanation attached.

NAME: ANCHORAGE, MUNICIPALITY OF
ADDRESS: 3000 ARCTIC BLVD.
ANCHORAGE AK 99503

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Form Approved
OMB No. 2040-0004

DISCHARGE MONITORING REPORT (DMR)	
AK0022551	001 A
PERMIT NUMBER	DISCHARGE NUMBER

MAJOR
(SUBR 02)
F - FINAL

FACILITY: JOHN M. ASPLUND WWTF----301 (H)
LOCATION: ANCHORAGE, AK 99502
ATTN: MARK PREMO P.E. GEN MGR. AWWU

MONITORING PERIOD						
06	07	01	TO	06	07	31

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

[illegible]

RECEIVED
AUG 14 2016
OFFICE OF U.S. CUSTOMS AND BORDER PROTECTION

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER

J. Kris Warren

Director, Treatment Division

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. §1001 AND 35 U.S.C. §1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE _____

(907)564-2799

06/08/08

AREA CODE NUMBER

YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Forms by WindowChem(707)864-0845:p/n11090:v5.01:4/1/96, Rev. 1/05, BN

The final effluent autosampler is normally taken off line on Saturdays, Mondays, and Wednesdays for line cleaning for approximately 1.5 hours each time; the composite samples for BODs, TSS, etc. are therefore slightly less than a 24HC on these days.